

Certificate



Aktiengesellschaft

No. z2861a-12-E

Customer:

Assmann Electronic GmbH
Auf dem Schüffel 3
D-58513 Lüdenscheid

Test sample(s):

- Outlet:
DIGITUS CAT 6a Keystone Jack, unshielded
Part-No.: DN-93602
- Panel:
DIGITUS CAT 6 Patch Panel, unshielded
Part-No.: DN-91624U
- Patchcord:
DIGITUS CAT 6 U-UTP Patch Cord, 2m, grey
Part-No.: DK-1611-020
- Data Cable:
DIGITUS CAT 6 U-UTP Installation Cable, Solid Wire, AWG23
Part-No.: DK-1611-V-1

Applied standard(s):

- ISO/IEC 11801 AMD 1 (2008-04)

Results:


Up to a bandwidth of **250 MHz** the sample meet the **Class E** limits of the specified standards and regulations.

Channel, Class E, 94m

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified Products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2861a-12-E**, from **March 01st, 2012** and shall only be applicable in conjunction with the test report.

Bexbach, March 01st, 2012


Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
Email: info@ghmt.de